

# Bighorn-Desert View Water Agency


## IMPORTANT INFORMATION

### – Mind “The Gap” –




The “Air Gap” required at the hauling station is 4-inches or more

An air gap, as it relates to water hauling, is the unobstructed vertical space between the water outlet and the flood level of a fixture. Air gaps of appropriate design are required for water safety by preventing any contaminants in the tank from flowing into the potable water system. A simple example is the space between a faucet and the sink rim (this space is the air gap). Water can easily flow from the faucet into the sink, but there is no way that water can flow from the sink into the faucet.



Air Gap And Effective Opening



**For More Information,  
Please Contact Our Agency At  
(760) 364-2315**